

VERIFICATION OF COMPLIANCE

No.: LVD GZES1511014381HS
Applicant: Gree Electric Appliances, Inc. of Zhuhai
Jinji West Road, Qianshan, Zhuhai, Guangdong, China
Manufacturer: Same as applicant
Product Name: Split-Type Air-Conditioner
Model No.: See ratings
Rating: See page 2 and 3
Protection against Electric Shock: Class I
Degree of Protection: Outdoor unit: IP24
Additional Information (if any): Refrigerant: R410A
This verification replaces LVD GZES1508010883HS.
Sufficient samples of the product have been tested and found to be in conformity with
Test Standard: EN 60335-2-40: 2003 + A11 + A12 + A1 + A2 + A13
EN 60335-1: 2012 + A11
EN 62233: 2008
as shown in the
Test Report Number(s): GZES140800943209

This Verification of Compliance is the result of testing samples of the product and verifying the testing documentation in accordance with the provisions of the relevant specific harmonised standards and the Low Voltage Directive (2006/95/EC). It does not imply an assessment of the whole production, technical documentation or fulfilment of other additional requirements in the Directive. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the directive are fulfilled and the Declaration of Conformity signed by the manufacturer.

The current Low Voltage Directive (2006/95/EC) will be replaced with Low Voltage Directive 2014/35/EU that will come effective on 20th April 2016. The testing samples of the product are in accordance with technical requirements of the Low Voltage Directive (2014/35/EU). The Technical documentation, Declaration of Conformity, markings etc. shall be brought into line with Low Voltage Directive (2014/35/EU). The manufacturer shall be aware about obligations of the manufacturer as stated in the Chapter 2 Article 6 of the Low Voltage Directive (2014/35/EU). The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the directive are fulfilled and proven with the Declaration of Conformity signed by the manufacturer.


Anson Luo
Laboratory Manager
SGS-CSTC


Per. 10/11
电子电气实验室


(The form of the CE marking)

2015-12-08

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.: LVD GZES1511014381HS

Other information added(Indoor units rating):

Rated voltage	Model No.	Rated input
220 V - 240 V; 50 Hz; 208 V - 230 V; 60 Hz	GMV-ND28T/A-T, GMV-ND36T/A-T, GMV-ND45T/A-T	48 W
	GMV-ND50T/A-T	50 W
	GMV-ND56T/A-T, GMV-ND63T/A-T	59 W
	GMV-ND71T/A-T, GMV-ND80T/A-T	68 W
	GMV-ND90T/A-T, GMV-ND100T/A-T	98 W
	GMV-ND112T/A-T, GMV-ND125T/A-T, GMV-ND140T/A-T	110 W
	GMV-ND160T/A-T	120 W
	GMV-ND22PLS/A-T, GMV-ND25PLS/A-T, GMV-ND28PLS/A-T	35 W
	GMV-ND32PLS/A-T, GMV-ND36PLS/A-T	43 W
	GMV-ND40PLS/A-T, GMV-ND45PLS/A-T, GMV-ND50PLS/A-T	52 W
	GMV-ND56PLS/A-T, GMV-ND63PLS/A-T	99 W
	GMV-ND71PLS/A-T	105 W
	GMV-ND80PLS/A-T	140 W
	GMV-ND90PLS/A-T, GMV-ND100PLS/A-T, GMV-ND112PLS/A-T	209 W
GMV-ND125PLS/A-T, GMV-ND140PLS/A-T	230 W	
220 V-240 V; 50 Hz	GMV-N22G/A2A-K, GMV-N22G/A3A-K, GMV-N22G/A4A-K, GMV-N22G/A8A-K, GMV-N22G/C9A-K, GMV-N22G/E3A-K, GMV-N28G/A2A-K, GMV-N28G/A3A-K, GMV-N28G/A4A-K, GMV-N28G/C9A-K, GMV-N28G/A8A-K, GMV-N28G/E3A-K	50 W
	GMV-N36G/A2A-K, GMV-N36G/A3A-K, GMV-N36G/A4A-K, GMV-N36G/A8A-K, GMV-N36G/C9A-K, GMV-N36G/E3A-K, GMV-N45G/A2A-K, GMV-N45G/A3A-K, GMV-N45G/A4A-K, GMV-N45G/A8A-K, GMV-N45G/C9A-K, GMV-N45G/E3A-K, GMV-N50G/A2A-K, GMV-N50G/A3A-K, GMV-N50G/A4A-K, GMV-N50G/A8A-K, GMV-N50G/C9A-K, GMV-N50G/E3A-K	60 W
	GMV-N56G/A2A-K, GMV-N56G/A3A-K, GMV-N56G/A4A-K, GMV-N56G/A8A-K, GMV-N56G/C9A-K, GMV-N56G/E3A-K, GMV-N63G/A2A-K, GMV-N63G/A3A-K, GMV-N63G/A4A-K, GMV-N63G/A8A-K, GMV-N63G/C9A-K, GMV-N63G/E3A-K, GMV-N71G/A2A-K, GMV-N71G/A3A-K, GMV-N71G/A4A-K, GMV-N71G/A8A-K, GMV-N71G/C9A-K, GMV-N71G/E3A-K	70 W


 Anson Luo
 Laboratory Manager
 SGS-CSTC




 (The form of the CE marking)

2015-12-08

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.: LVD GZES1511014381HS

Other information added(Outdoor units rating):

Rated voltage	Model No.	Rated input
380 V - 415 V 3N; 50 Hz / 60 Hz	GMV-224WM/B-X	cooling: 8800 W; heating: 8000 W
	GMV-280WM/B-X	cooling: 11700 W; heating: 10700 W
	GMV-335WM/B-X	cooling: 13800 W; heating: 13000 W
	GMV-400WM/B-X	cooling: 16100 W; heating: 15200 W
	GMV-450WM/B-X	cooling: 18600 W; heating: 17600 W
	GMV-280WL/A-X	cooling: 12100 W; heating: 11800 W
	GMV-250WL/A-X	cooling: 11300 W; heating: 11000 W
	GMV-224WL/A-X	cooling: 8400 W; heating: 8260 W
380 V - 415 V 3N; 50 Hz	GMV-224WM/A-M	cooling: 8800 W; heating: 8000 W
	GMV-280WM/A-M	cooling: 11700 W; heating: 10700 W
	GMV-335WM/A-M	cooling: 13800 W; heating: 13000 W

Anson Luo (The form of the CE marking)
 Laboratory Manager
 SGS-CSTC

2015-12-08

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)